



2026 ANNUAL SCHOOL CERTIFICATION

Required under the Authority of the Clean Drinking Water Access Act,
2023 PA 154 to meet Michigan's Filter First law.



School Information

School Name: Parkview Elementary School
Entity ID: SCC-12450
School District: Charlotte Public Schools
Address: 301 E KALAMO HWY
CHARLOTTE, MI 488139199
County: Eaton
Grade Levels: KG,1,2,3

Parkview Elementary School

Certified to meet requirements of the Clean
Drinking Water Access Act, 2023 PA 154.

Certified by: ANDY CZAICA

Certification Date: 8/18/2026

Filter First requires schools to report the yearly status of the following:

Status	Requirement
✓	The Drinking Water Management Plan (DWMP) has been completed for this building: Yes The DWMP is available to EGLE, school staff, parents and guardians of children enrolled in the school, and made available to the general public upon request.
✓	The building has the minimum number of bottle filling stations: Yes For every 100 students and staff, the building must have at least one bottle-filling station compliant with all Filter First requirements. Number of Eligible Bottle Filling Stations: 23 Reported School Population: 230
✓	Filters are properly maintained: Yes Filter cartridges are regularly replaced at each filtered bottle-filling station and filtered faucet following manufacturer's instructions or recommendations of EGLE.
✓	Samples were collected and tested for lead in drinking water: Yes Completed annual water sampling and testing of the filtered water at each filtered bottle-filling station and filtered faucet.
—	Followed lead detected remediation actions: No lead was detected Every school is required to take action to reduce the risk of lead exposure in drinking water if sample results detected lead.